

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 2019-06-27-EX1216  
**Report Reference** EX1216-2019-03-06  
**Issue Date** 2019-06-27

**Issued to:** Fire and Hazard Control Equipment Co. Ltd.  
**Manufacturer Company:** PO Box 8401  
69th Street, II Industrial Area  
Dammam 31482 SAUDI ARABIA

**Listed Company:** Ansul – A Tyco Fire Protection Products Brand  
1 Stanton St  
Marinette, WI 54143-2542

**This certificate confirms that representative samples of** Dry-Chemical Fire Extinguishers, Hand and Wheeled  
See Addendum for Model information

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/UL 299 – Dry Chemical Fire Extinguishers  
ANSI/UL 711 – Rating and Fire Testing of Fire Extinguishers

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 2019-06-27-EX1216  
**Report Reference** EX1216-2019-03-06  
**Issue Date** 2019-06-27

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Cartridge-operated type

Model*	Nominal Agent Capacity, lb	Min Use Temp, °F	Rating	Marine Classification	
				Type A Size	Type B:C Size
Ammonium phosphate					
A-10-G-1	8.5	-40	4-A:40-B:C	Size II	Size I
A-20-G-1	17.0	-40	6-A:60-B:C	Size II	Size II
A-30-G-1	25.0	-40	10-A:80-B:C	Size II	Size III
Potassium bicarbonate					
K-10-G	9.0	-40	60-B:C	-	Size II
K-20-G	18.0	-40	80-B:C	-	Size III
K-30-G	27.0	-40	120-B:C	-	Size IV

\*Models with the prefix "I" are provided with a pressure indicator.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

